## Homework #2 – Calculating Heat Loss in Buildings Due: 8/30

## Name: Solution

 Calculate the total heat loss due to transmission during a 24-hour period for a flat roof 90 ft X 135 ft. The roof is constructed per the detail below. The inside temperature is 70 °F and the outside temperature is 52 °F. Assume winter conditions. Show all calculations.



		R (Between joist)	R (At joist)
1.	Air film outside	0.17	0.17
2.	3/8 in. Built-up roofing	0.33	0.33
3.	5/8 in. Plywood Sheathing	0.77	0.77
4.	1 ½ in. Air space	1.00	
5.	R-15 Fiberglass Batt Insulation	15.00	
6.	5/8 in. Gypsum board	0.56	0.56
7.	Air film inside	0.68	0.68
8.	Nominal 2-in x 12-in Doug Fir Joist @ 24 in. o.c (1.5" x 11.25") R=1.00		11.25
R <sub>Total</sub>		18.51	13.76
R <sub>Total</sub> (Average)		18.21	
U-Factor (Use Three Decimals)		0.055	

Determine the average U-Factor for the ceiling



$$\begin{split} R_{AVG} &= (1.5''/24'') \ x \ 13.76 + (22.5''/24'') \ x \ 18.51 = 0.86 + 17.35 = 18.21 \\ U_{AVG} &= 1 \ / \ R_{AVG} = 1 \ / \ 18.21 = 0.055 \ Btu/hr \ x \ ^{\circ}F \ x \ ft^2 \end{split}$$

## Total Heat Loss

Q = U x A x ΔT x 24 hr = 0.055 Btu/hr x °F x ft<sup>2</sup> x (90 ft x 135 ft) x (70°F - 52°F) x 24 hr = 12,029 BTU

2. An exterior wall is made up of 8" of stone (R= 0.08 per inch), 3" of foamed-in-place polyurethane, and 0.75" Plywood, and 5/8" gypsum board. Determine the total R-value and U-Factor for the wall. Use the lookup table provided in class. Assume winter.

Component	R-Value	
Wall – Outside Air Film	0.17	
8" stone	0.64	
3" foamed-in-place polyurethane	18.75	
¾" plywood	0.93	
5/8" gypsum board	0.56	
Inside Air Film	0.68	
Total Wall Assembly R-Value	21.73	
U-Factor (Use Three Decimals)	0.046	

3. If the wall in problem 2 is 40 ft long and 12 ft. high what is the heat loss through the wall for an indoor winter design temperature of 78 °F and an outside temperature of 42°F?

<u>Rate of Heat Loss</u> q = U x A x  $\Delta$ T = 0.046 Btu/hr x °F x ft<sup>2</sup> x (40 ft x 12 ft) x (78 °F - 42°F) = 795 Btuh

Heat loss per Day Q = U x A x  $\Delta$ T = 0.046 Btu/hr x °F x ft<sup>2</sup> x (40 ft x 12 ft) x (78 °F - 42°F) x 24 hr = 19,080 Btu