

CMGT 235 – Electrical and Mechanical Systems

In Class Activity #1 – Heat Load Calculation for a Small Building

Name: Solution #2

Name: _____

Name: _____

R-Value Table

| Building Component | R-Value |
|-------------------------|-----------------------------|
| Wildebeest snout siding | 0.81 |
| Weevil Hide sheathing | 0.98 |
| Wookie fiber insulation | 3.78 per inch of thickness |
| Wombat Fur insulation | 3.70 per inch of thickness |
| Wabbit foot wallboard | 16.80 per inch of thickness |
| 2x4 Wood Stub | 4.38 |
| Walleye Scales | 0.78 |
| Walrus Tusk | 0.33 |
| Windows per/sf | 2.30 |
| Doors | 5.60 |
| Inside Air Film | 0.68 |
| Outside Air Film | 0.17 |
| Air space | 0.72 per inch of thickness |

1. Determine the R-Value and U-Factor for the Wall:

A. Wall Assembly (At Framing)


| Wall R Value | R-Value | | Total R-Value |
|--------------------------------------|---------|--------|---------------|
| Outside Air Film | 0.17 | | 0.17 |
| Wildebeest Snout Siding | 0.81 | | 0.81 |
| Weevil Hide Sheathing | 0.98 | | 0.98 |
| 2x4 Wood Stud | 4.38 | | 4.38 |
| 1/2" Wabbit Foot Wallboard | 16.80 | per/in | 8.40 |
| Inside Air Film | 0.68 | | 0.68 |
| Total R | | | 15.42 |
| U-Factor (use three decimals) | | | 0.065 |

B. Wall Assembly (At Insulation)

| Wall R Value | R-Value | | Total R-Value |
|--------------------------------------|---------|--------|---------------|
| Outside air film value | 0.17 | | 0.17 |
| Wildebeest snout siding | 0.81 | | 0.81 |
| Weevil Hide sheathing | 0.98 | | 0.98 |
| 3-1/2" Wookie fiber insulation | 3.78 | per/in | 13.23 |
| 1/2" Wabbit foot wallboard | 16.80 | per/in | 8.40 |
| Inside air film value | 0.68 | | 0.68 |
| Total R | | | 24.27 |
| U-Factor (use three decimals) | | | 0.041 |

C. Determine the average U-Factor for the wall assembly. SHOW ALL WORK

Wall Assembly



Hint: Determine the percentage of wall that is 2x4 stud and the percentage that is insulated.

$$\text{U-Factor Average} = 0.065 \times (1.5/8) + 0.041 \times (6.5/8) = 0.065 \times 0.1875 + 0.041 \times 0.8125 = 0.045$$

D. Ceiling Assembly


| Ceiling R Value | R-Value | | Total R-Value |
|--------------------------------------|---------|--------|---------------|
| 18" Wombat fur | 3.70 | per/in | 66.60 |
| 1/2" Wabbit foot wallboard | 16.80 | per/in | 8.40 |
| 10" air space | 0.72 | per/in | 7.20 |
| Inside air film value | 0.68 | | 0.68 |
| Outside air film value | 0.17 | | 0.17 |
| Total R | | | 83.05 |
| U-Factor (use three decimals) | | | 0.012 |

2. Building Construction Data
A. Calculate Building Volume



Building Dimensions

| | |
|--|-------------------------|
| Length (ft) | 160 |
| Width (ft) | 100 |
| Ceiling Height (ft) | 15 (1&2) and 12 ft (3) |
| Volume per floor (ft ³) = | 480,000 and 192,000 |
| Total Building Volume (ft ³) = | 672,000 |



B. Calculate Wall, Window, and Door Area

Wall Schedule

| Description | Length (ft) | Height (ft) | Area (ft ²) |
|--------------|-------------|-------------|-------------------------|
| North | 160 | 42 | 6720 |
| East | 100 | 42 | 4200 |
| South | 160 | 42 | 6720 |
| West | 100 | 42 | 4200 |
| Total | | | 21,840 |

Window Schedule

| Quantity | Width (ft) | Height (ft) | Area (ft ²) |
|--------------|------------|-------------|-------------------------|
| 30 | 8 | 6 | 1440 |
| Total | | | 1440 (per floor) |

Door Schedule

| Quantity | Width (ft) | Height (ft) | Area (ft ²) |
|--------------|------------|-------------|-------------------------|
| 8 | 4 | 8 | 256 |
| 4 | 4 | 10 | 160 |
| Total | | | 416 |

C. Calculate Net Wall Area

Net Wall Area = Total Wall Area – Total Window Area – Total Door Area

Net Wall Area = 21,840 – 4,320 – 416 = 17,104 ft²

3. HEAT LOAD CALCULATION

A. Heat Loss Due to Infiltration

Method 1

Convection: BTUH heat gain/loss due to infiltration

$$q_{\text{infil}} = C \times \text{ACH} \times V \times \Delta T$$

| | | |
|----------------------|---------------------------|-------------------------|
| C = | 0.018 Btu/ft ³ | |
| ACH = | | 3.0 |
| V = | | 672,000 ft ³ |
| ΔT = | | 42 °F |
| q _{infil} = | | 1,524,096 BTUH |

(Round q to Whole Number)

Method 2 (check of Method 1)

Step 1: Find cfm

$$\text{CFM} = (\text{ACH} \times V) / 60$$

| | | |
|-------|--|-------------------------|
| ACH = | | 3.0 |
| V = | | 672,000 ft ³ |
| time | | 60 min/hr |
| CFM = | | 33,600 |

$$\text{BTUH} = \text{CFM} \times 1.08 \times \Delta T$$

Step 2: Insert step 1 cfm

| | | |
|--------|--|-----------|
| CFM = | | 33,600 |
| 1.08 | | |
| ΔT = | | 42 °F |
| BTUH = | | 1,524,096 |

B. Heat Loss Due to Ventilation

Convection: BTUH heat/gain loss due to ventilation

$$q_{\text{ventilation}} = 1.08 \times \text{cfm}_{\text{total vent.}} \times \Delta T \text{ Heating Coil}$$

| | Number of | CFM |
|------------------|-----------|----------------------------|
| 15 CFM/Wallaby X | 80 = | 1200 CFM |
| 5 CFM/Weasels X | 900 = | 4500 CFM |
| | | 5700 CFM total ventilation |

| | | |
|----------------------------------|--|--------------|
| CFM _{total ventilation} | | 5700 |
| ΔT = | | 47 °F |
| q _{ventilation} | | 289,332 BTUH |

(Round q to Whole Number)

C. Design Conditions

| Infiltration Data | |
|-------------------|---------|
| Building Volume | 672,000 |
| Air Changes/Hour | 3.0 |
| Infiltration CFM | 33,600 |

| Winter Design Criteria | |
|-------------------------|--------------|
| Mixed Air Temp | 55 °F |
| Return Air Temp | 62 °F |
| Outside Temp | 36 °F |
| Supply Air Temp | 108 °F |
| Daytime Setpoint | 78 °F |
| Design ΔT | 42 °F |
| Heating Coil Air ΔT | 47 °F |
| Heating Coil Water ΔT | 27 °F |

D. Heat Loss Due to Transmission (Round q to Whole Number)

| Component | U-Factor (Btu/h x ft ² x °F) | Area (ft ²) | ΔT (°F) | q _{Transmission} = U x A x ΔT (BTUH) |
|---|--|-------------------------|---------|--|
| Walls (Net) | 0.045 | 17,104 | 42 | 32,327 |
| Windows | 0.435 | 4,320 | 42 | 78,926 |
| Doors | 0.179 | 416 | 42 | 3,127 |
| Ceiling | 0.012 | 16,000 | 42 | 8,064 |
| Total Envelope Heat Loss Due to Transmission | | | | 122,444 |

E. Heat Loss Due to Convection (From Page 5)

| | |
|--|------------------|
| q_{Infiltration} (BTUH) | 1,524,096 |
| q_{Ventilation} (BTUH) | 289,332 |

F. Total Building Heat Load (q_{total} = q_{Transmission} + q_{Infiltration} + q_{Ventilation})

| | |
|------------------------------------|------------------|
| Total Heat Coil Load (BTUH) | 1,935,872 |
|------------------------------------|------------------|

Extra Credit

4. FAN AND PUMP DATA

A. CFM Req. to move across heating coil = [Total Space Heat Loss/Gain / Heating coil air ΔT] * 1.08

$$= (1,935,872 / 47) \times 1.08 = 44,484 \text{ CFM}$$

B. GPM Req. to flow through heating coil = Total Coil Load / (Heating coil water ΔT * 500)

$$= 1,935,872 / (27 \times 500) = 143 \text{ GPM}$$