



2 FIRE PROTECTION HANGER DETAIL NOT TO SCALE

COPYRIGHT NOTICE
THIS DRAWING IS THE PROPERTY OF THE ABOVE REFERENCED PROFESSIONAL AND SHALL NOT BE USED FOR ANY PROJECT OTHER THAN THE SPECIFIC PROJECT AND SPECIFIED HEREIN AND CANNOT BE REPRODUCED IN ANY MANNER WITHOUT THE EXPRESS WRITTEN PERMISSION FROM THE PROFESSIONAL.

ISSUE RECORD

DATE	DESCRIPTION
09/16/2016	PERMIT SET
02/13/2017	BID SET

PROFESSIONAL SEAL

PROFESSIONAL IN CHARGE
ERIC WOLF
PROJECT MANAGER
ERIC WOLF
QUALITY CONTROL
ERIC WOLF
DRAWN BY
ANDREW STRACK

PROJECT NAME
WHOLE FOODS MARKET

KENNESAW, GA

1300 ERNEST BARRETT PKWY, SUITE 500 KENNESAW, GA 30152



PROJECT NUMBER
20150922.0

SHEET TITLE
FIRE PROTECTION CEILING PLAN - FIRST FLOOR

SHEET NUMBER
FP200

PIPE LEGEND

SYMBOL	DESCRIPTION
(Symbol)	EXISTING CROSSMAN/BRANCHLINE
(Symbol)	EXTENDED CROSSMAN/BRANCHLINE

SPRINKLER SCHEDULE

SYM	QTY	K=	TEMP	MAKE & MODEL	RESP	TYPE
● 32	5.6	1/2"	155 °F	TYCO DS-1	Standard	Pendant
● 149	5.6	1/2"	200 °F	TYCO TY-B	Standard	Pendant
○ 6	5.6	1/2"	200 °F	TYCO TY-B on Sprig	Standard	Upright

Total New Heads: 187

KEYNOTES FP200

NOTE	DESCRIPTION
1	EXISTING 4" WET RISER TO REMAIN
2	EXISTING 3" DRY RISER TO REMAIN
3	EXISTING 1 1/2" BRANCHLINE TO REMAIN (TYPICAL)
4	EXISTING 3" CROSSMAN TO REMAIN
5	EXISTING 2 1/2" CROSSMAN TO REMAIN
6	DROPS TO BEHIND WALL SO AS NOT TO BE VISIBLE FROM SALES AREA
7	EXISTING HEAD MOVED AWAY FROM FULL HEIGHT WALL

GENERAL NOTES:

- ALL EXTENDING PIPE 1" UNLESS OTHERWISE NOTED
- SYSTEMS ARE DESIGNED AND ARE TO BE INSTALLED PER NFPA 13, 2016 ED.
- ALL PIPE 1 1/2" AND OVER TO BE SCH. 10 GROUNDED WITH GROUNDED FITTINGS
- ALL PIPE 1 1/4" AND UNDER TO BE SCH. 40 THREADED WITH DUCTILE IRON FITTINGS
- SYSTEMS ARE DESIGNED ORDINARY HAZARD 2 WITH A MAXIMUM HEAD SPACING OF 130 SQ. FT.

1 FIRE PROTECTION FIRST FLOOR PLAN
1/8" = 1'-0"

