CMGT 235 - Electrical and Mechanical Systems

In Class Activity #6 - Residential Service Entrance

WRITE NEATLY - Include all Names if working as a Group

Name	Solution
Name	
Name	

1. Complete the Single-Family Dwelling Service-Entrance Calculations (Standard) Form for the following:

- 4	Complete the single raining betwee Entrance calculations (standard) roini for the following.				
	2900 ft ² of Living Floor Area			Trash Compactor: 15 AMPS, 120V	
	4	Small-Appliance Branch Circuits	4	Attic Fans: 1/4 HP, 120V	
	2	Laundry Branch Circuits	2	Garage Door Openers: ¾ hp, 120V	
	1	Electric Clothes Dryer: 7.2 kW, 240V	1	Air Handler (blower motor): 4 AMPS, 120V	
	2	Wall-mounted Ovens: 6 kW, 240V	No	te: Blower for AC and Heater	
	1	Electric Range: 5 kW, 240V	1	AC Compressor: 18 AMPS, 240V	
	1	Under-Cabinet Microwave Oven: 10A, 120V	1	Condenser Fan Motor: 3 AMPS, 120V	
	1	Dishwasher: 15 AMPS, 120V	1	Electric Heater: 16kW, 240V	
	1	Garbage Disposal: ½ hp, 120V	1	Freezer: 6.2 A, 120V	

2. Show Calculation for:

Step 7. Electric Range, Wall-Mounted Ovens, Counter-Mounted Cooking Units

Wall-mounted ovens and Electric Range are supplied from a single branch circuit and located in the same room. See: Table 250.55, Note 4

2 ovens
$$2 \times 6 \times w = 12 \times w$$

1 Ronge $1 \times 5 \times w = \frac{5}{17} \times w$

1 Ronge $1 \times 5 \times w = \frac{5}{17} \times w$

3. Show Calculation for:

Step 9. Electric Furnace. Air Conditioner, Heat Pump Electric Heater (List Components)

17 KW-12 KW = 5 KW

Air Conditioner (List Components)

1310Wer 480 VA compressor 18A x 240 V = 4320 VA Condenses Fan 3A x 120 V = 360 VA

5160 VA

4. Show Calculation for:

Step 21. Raceway Size - Ungrounded Conductors and Neutral Conductor

QTY	GAUGE	TYPE	Cross-Section Area (4-decimals)
2	3/0	THWN	0.2679 x2 = 0.5358
1)	THWN	0.1562 ×1 = 0.1562

Trade Size EMT

Total Cross-Section Area 0.692 in 2

5. Show Calculation for Raceway Size for Ungrounded Conductors, Neutral Conductor, and Bare Grounding Electrode Conductor.

QTY	GAUGE	TYPE	Cross-Section Area (4-decimals)
2	3/0	THWN	0.2679 ×2 = 0.5358
1	1	THWN	0.1526 ×1 = 0.1562
1	2	Bare	0.0564 ×1 = 0.0564

Trade Size EMT

Total Cross-Section Area 0.7484,32

Bane 2
$$d = 0.268 \text{ in}$$

 $A = \pi d^2 = \pi \left[0.268 \text{ in}\right]^2 = 0.0564 \text{ in}^2$

SINGLE-FAMILY DWELLING SERVICE-ENTRANCE CALCULATIONS

1. General Lighting Load (220.12).

2900 ft² @ 3 VA per ft²

= 8700 VA

Note: Included in this floor area calculation are all lighting outlets and general-use receptacles. Do not include open porches, garages, or unused or unfinished spaces not adaptable for future use. See NEC 220.12, Table 220.12, and 220.14(J).

2. Minimum Number of 15-ampere Lighting Branch Circuits.

then, $\frac{\text{amperes}}{15}$ $\frac{72.5}{15}$ $\frac{\text{amperes}}{15}$ $\frac{4.83}{15}$ = $\frac{5}{15}$ -ampere branch circuits

3. Small-Appliance Load [210.11(C)(1), 220.52(A), and 210.52(B)].

(Minimum of two 20-ampere branch circuits)

4 branch circuits @ 1500 VA each

= 6000 VA

4. Laundry Branch Circuit [210.11(C)(2), 220.52(B), and 210.52(F)].

(Minimum of one 20-ampere branch circuit)

branch circuit(s) @ 1500 VA each

= 3000 va

5. Total General Lighting, Small-Appliance, and Laundry Load.

Lines 1 + 3 + 4

= 17,700 VA

6. Net Calculated General Lighting, Small-Appliance, and Laundry Loads (less ranges, ovens, and "fastened-in-place" appliances). Apply demand factors from Table 220.42.

a. First 3000 VA @ 100%

a. First 3000 VA @ 100% = 3000 VA b. Line 5 17,700 - 3000 = 14,700 @ 35% = 5145 VA

7. Electric Range, Wall-Mounted Ovens, Counter-Mounted

Cooking Units (Table 220.55).

= (0,000 VA

8. Electric Clothes Dryer (Table 220.51).

= 7200 VA

9. Electric Furnace (220.54).

Air Conditioner, Heat Pump (Article 440).

(Enter largest value, 220.60)

= 16480 VA

10. Net Calculated General Lighting, Small-Appliance, Laundry,

Ranges, Ovens, Cooktop Units, HVAC. Lines 6 + 7 + 8 + 9

= 41,825 VA

Appliance		VA Load
Water heater:		= VA
Dishwasher:		= 1800 VA 15A +120U
Garage door opener:		= 3312 VA 13,8 A x 120V 72
Food waste disposer:		= 1176 VA 9,8A X120V
Water pump:		=VA
Gas-fired furnace:		=VA
Sump pump:		=VA
Other: Freezer		= 744 VA 6,2A Y120V
MI croware over		= 1200 VA 10A + 120 V
Trash Compactor		= 1800 VA 15 A + 120 V
Attic Fans		= 2784 VA 5.84 x120V x 4
1	Total	= 12,816 VA

12. Apply 75% Demand Factor (220.53) if Four or More "Fastened-in-Place" Appliances. If Less Than Four, Figure @ 100%. Do not include electric ranges, electric clothes dryers, electric space heating, or air-conditioning equipment.

Line 11 Total:
$$12,816 \times 0.75$$

13. Total Calculated Load (Lighting, Small-Appliance, Ranges, Dryer, HVAC, "Fastened-in-Place" Appliances).

14. Add 25% of Largest Motor (220.50 and 430.24).

Note: The largest motor can be difficult to determine because nothing is in place when service-entrance load calculations are made. It might be an air-conditioning unit or a heat pump. If the dwelling is cooled by an evaporative cooler, the largest motor might be a water pump, a large attic exhaust fan, a large food waste disposer, or a sump pump. For simplicity in this example, the water pump was chosen. The additional 25% of the largest motor is a small portion of the total service-entrance load calculation.

$$= 51,887 \text{ VA}$$


16. Minimum Ampacity for Ungrounded Service-Entrance Conductors.

Amperes =
$$\frac{\text{Line 15}}{240} = \frac{51,887}{240}$$
 $\frac{216 \text{ A} \times 0.83}{216 \text{ A} \times 0.83} = 179 \text{ A} = \frac{216}{216}$ amperes

17. Ungrounded Conductor Size (copper).

Note: Table 310.15(B)(7) may be used only for 120/240-volt, 3-wire, residential single-phase service-entrance conductors, service lateral conductors, and feeder conductors that serve as the main power feeder to a dwelling unit.

18. Minimum Ampacity for Neutral Service-Entrance Conductor, 220.61 and 310.15(B)(7). Do Not Include Straight 240-Volt Loads.



e. Line d total @ 75% demand factor if four or more per 220.53, otherwise use 100%.

f. Add 25% of largest 120-volt motor.

$$\frac{1800}{1800} \times 0.25 = \frac{450}{1000} \text{ VA}$$

$$\text{Total} = \frac{1000}{2} \text{ VA}$$

$$= \frac{1000}{2} \text{ VA}$$

$$= \frac{30,247}{240} \text{ VA}$$

$$= \frac{126}{2} \text{ amperes}$$

19. Neutral Conductor Size (copper)(220.61).

Note: NEC 310.15(B)(7) permits the neutral conductor to be smaller than the ungrounded "hot" conductors if the requirements of 215.2, 220.61, and 230.42 are met. NEC 220.61 states that a feeder or service neutral load shall be the maximum unbalance of the load determined by Article 220. When bare conductors are used with insulated conductors, the conductors' ampacity is based on the lowest temperature rating of the insulated conductors in the raceway, 310.15(B)(4). The neutral conductor shall not be smaller than the grounding electrode conductor, 250.24(C)(1).

Obtain dimensional data from Table 1, Table 4, Table 5, and Table 8, Chapter 9, NEC.

SHOW ALL WORK FOR SIZING RACEWAY ON HANDOUT PROVIDED. DO NOT WRITE HERE.