

(2) 4" E.C.'S (WITH (1) PULL WIRE IN EACH) BUILDING COMMUNICATION SERVICE ENTRANCE CONDUITS. REFER TO E1.1 FOR CONTINUATION AND FINAL UTILITY CONNECTION POINT.

BUILDING SERVICE ENTRANCE RATED FEEDERS, REFER TO SHEET E5.1 FOR SIZE AND QUANTITY.

FOR FUTURE USE

UTILITY COMPANY'S PRIMARY SERVICE ENTRANCE FEEDERS, REFER TO SHEET E5.1 FOR SIZE AND QUANTITY. REFER TO E1.1 FOR CONTINUATION AND FINAL UTILITY CONNECTION POINT.

PROVIDE CORE HOLE(S) THROUGH BASEMENT WALL FOR BUILDING SERVICE FEEDERS

NORMAL DIST. BOARD "MDB"

TVSS CABINET

PANEL "HB1"

ENLARGED SERVICE YARD PLAN - POWER

SCALE: 3/16" = 1'-0"

