



**FIRST FLOOR PLAN - LIGHTING**  
SCALE: 3/16" = 1'-0"

- LIGHTING GENERAL NOTES:**
1. REFER TO SHEETS E0.1, E5.1, E6.1, E7.0, FOR ELECTRICAL SYMBOL LEGEND, ELECTRICAL PANEL SCHEDULES, LIGHT FIXTURE SCHEDULE, AND ELECTRICAL RISER DIAGRAM.
  2. ALL BRANCH CIRCUITS ARE CONNECTED TO PANELBOARDS "H1" UNLESS NOTED OTHERWISE.

- NOTES:**
1. PROVIDE COMBINATION SINGLE THROW, SINGLE POLE SWITCH AND BUILT-IN MOTION SENSOR FOR CONTROL OF LIGHTING (TYPICAL). COMBINATION SWITCH SHALL BE NOVITAS MODEL #01-400, OR EQUAL. MOTION SENSOR SHALL MEET NEMA GUIDE "WD-7" COVERAGE PATTERN. PROVIDE ALL SENSORS, SWITCHPACKS AND CONTROL WIRING. SET TIME DELAY FOR SENSOR TO TURN "OFF" LIGHTS IN AREAS TO 5 MINUTES.
  2. MOUNT TOP OF LIGHT FIXTURE AT 12'-0" AFF (TYPICAL OF 3).

