

# **ACME CONSTRUCTION CO**

1565 Cummins Dr., Modesto, CA, 95358

Phone: 209.523.2674

Fax: 209.523.0213

Date: August 30, 2021

<b>TO:</b>	<b>COMPANY:</b>	<b>FAX:</b>	<b>PHONE:</b>
Students	North State Electric		530-519.1147

**Project:** Accubid Office Building

**Location:** 1010 Marauder Street  
Chico, CA 95973

**Trade:** Electrical

## **ADDENDUM #2**

Furnish and install a 4-channel digital time switch in the Basement Electrical Room to control the parking lights, exterior building lights, and building corridor lights. Unit shall have NEMA 1 indoor enclosure as standard.

Lighting Control for parking, exterior and corridor lighting shall be installed as follows:

### Basement

Furnish and install in the Basement Electrical Room two (2) 3-pole 30 amp contactors NEMA 1 for the parking light and exterior building light circuits to be controlled.

### First Floor

Furnish and install in the First Floor Electric Room One (1) 3-pole 30 amp contactor NEMA Type 1 for the corridor light circuits to be controlled.

Time switch to be 120V from Panel L1

Contactors coil circuits to be 24VAC