

ACME CONSTRUCTION CO

1565 Cummins Dr., Modesto, CA, 95358

Phone: 209.523.2674

Fax: 209.523.0213

Date: August 30, 2021

| TO: | COMPANY: | FAX: | PHONE: |
|------------|----------------------|-------------|---------------|
| Estimating | North State Electric | | 530-519.1147 |

Project: Accubid Office Building

Location: 1010 Marauder Street
Chico, CA 95973

Trade: Electrical

ADDENDUM #1

NIGHT LIGHTING – fixtures for 24 hour night lighting shall be as follows:

Basement – 3 Type A2 – 1 at S.W. of GL C/3 corridor B01, 1st fixture N. of GL 3 in elevator lobby, and center fixture in corridor B04. Circuit HB1-6.

1ST FLOOR – Type A2 on GL B corridor 117, center type D fixture S. of GL 3 lobby 101, center type C fixture S. of GL 2 lobby 100, Type A2 on GL C corridor 112. Circuit H1-8.

2ND TO 4TH FLOOR – 4 Type A – 1 @ 7' S & 6' E of GL E/3, 1 @ 7' S & 6' W of GL B/3, 1 @ 10' N & 3' W of GL E2, 1 @ 10' N & 3' W of GL B/2, 1 Type C – center fixture in elevator lobby. All five fixtures to be on circuit H-5 from the applicable floor panel.